Typical Fire Hydrant Assembly

All fire hydrant laterals will have tracer wire that is accessible in a 4” round hand hole with cover, flush with grade, located within 6” of either side of fire hydrant.